

NATIONAL ANNEX
TO
CYS EN 1998-6:2005 Eurocode 8: Design of structures for
earthquake resistance
Part 6: Towers, masts and chimneys

Public Enquiry Draft

Period of Enquiry

November 19th 2007 to January 14th 2008

Readers are advised that this is a draft document and subject to change

Prepared by: Eurocodes Committee
Ministry of Interior / Technical Chamber of Cyprus

INTRODUCTION

This National Annex has been prepared by the Eurocodes Committee of the Technical Chamber of Cyprus which was commissioned by the Ministry of Interior of the Republic of Cyprus

NA 1 SCOPE

This National Annex is to be used together with CYS EN 1998-6:2005

This National Annex gives:

- (a) Nationally determined parameters for the following clauses of CYS EN 1998-6:2005 where National choice is allowed (see Section NA 2)
 - 1.1(2)
 - 3.1(1)
 - 3.5(2)
 - 4.1(5)P
 - 4.3.2.1(2)
 - 4.7.2(1)P
 - 4.9(4)
- (b) Decisions on the use of the Informative Annexes A to F (see Section NA 3)
- (c) References to non-contradictory complementary information to assist the user to apply CYS EN 1998-6:2005. In this National Annex such information is provided for the following clauses in CYS EN 1998-6:2005 (see Section NA 4)

NA 2 NATIONALLY DETERMINED PARAMETERS

NA 2.1 Clause 1.1 (2) Scope of CYS EN 1998-6:2005

Annexes A to F are informative and can be used in the design of towers, masts and chimneys.

NA 2.2 Clause 3.1 (1) Definition of the seismic input

The rotational component of the ground motion should be taken into account for structures taller than 80m in regions where the product $a_g S$ exceeds 0,25g.

NA 2.3 Clause 3.5 (2) Long period components of the motion at a point

In the cases where site-specific studies have been carried out with particular reference to the long-period content of the motion, the value of the lower bound factor β is 0,1.

NA 2.4 Clause 4.1 (5)P Importance factors

The value of the importance factor γ_I for towers, masts and chimneys is:

1. Importance Class I, $\gamma_I=0,8$
2. Importance Class II, $\gamma_I=1,0$
3. Importance Class III, $\gamma_I=1,2$
4. Importance Class IV, $\gamma_I=1,4$

PUBLIC ENQUIRY DRAFT

National Annex to CYS EN 1998-6:2005 Eurocode 8: Design of Structures for Earthquake Resistance
Part 6: Towers, masts and chimneys

NA 2.5 Clause 4.3.2.1 (2) Seismic action

The detailed or additional conditions to be applied for the lateral force method of analysis are a total height H not greater than 60m and an importance class I or II.

NA 2.6 Clause 4.7.2 (1)P Partial safety factors for materials

Refer to CYS EN 1998-1:2004 subclauses 5.2.4(3), 6.1.3(1), 7.1.3(1) and 9.6(3) for the partial safety values of steel, concrete, structural steel and masonry.

NA 2.7 Clause 4.9 (4) Reduction factor at damage limitation state

The reduction factor v that may be applied to the design seismic action is:

1. Importance Class I and II, $v=0,5$
2. Importance Class III and IV, $v=0,4$

NA 3 DECISION ON USE OF THE INFORMATIVE ANNEXES A , B, C, D, E AND F

NA 3.1 Annex A

Annex A is informative and may be used.

NA 3.2 Annex B

Annex B is informative and may be used.

NA 3.3 Annex C

Annex C is informative and may be used.

NA 3.4 Annex D

Annex D is informative and may be used.

NA 3.5 Annex E

Annex E is informative and may be used.

NA 3.6 Annex F

Annex F is informative and may be used.

NA 4 REFERENCES TO NON-CONTRADICTORY COMPLEMENTARY INFORMATION

None